

TÜV SÜD
ZERTIFIKAT ◆ CERTIFICATE ◆ CERTIFICADO ◆ CERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆



Product Service

CERTIFICATE

No. B 011675 0010 Rev. 00

**Holder of Certificate: Meltem Lüftungsgeräte
GmbH & Co. KG**
Am Hartholz 4
82239 Alling
GERMANY

Certification Mark:



**Product: Fans
Ventilation appliance**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 028-713157747-000

Valid until: 2025-01-19

Date, 2020-01-29 (Konrad Prenner)



Product Service

CERTIFICATE

No. B 011675 0010 Rev. 00

Model(s):

Model: VARIO II

**Types: V-II 30; V-II 30-BM-N; V-II 30-BM-I; V-II 30-N;
V-II 30-I; V-II 60; V-II 60-BM-N; V-II 60-BM-I; V-II 60-N;
V-II 60-I; V-II 60-F; V-II 100; V-II 100-BM-N; V-II 100-BM-I;
V-II 100-N; V-II 100-I; V-II 100-F; V-II 30/60; V-II 30/60-NZ;
V-II 30/60-K; V-II 30/60-KF; V-II 30/60-KF-LX;
V-II 30/60-KZ; V-II 30/60-F; V-II 30/100; V-II 30/100-NZ;
V-II 30/100-K; V-II 30/100-KF; V-II 30/100-KF-LX;
V-II 30/100-KZ; V-II 30/100-F; V-II 30/60/100**

Parameter:

Model:	Vario II	Vario II	Vario II	Vario II	Vario II
Type:	V-II 30 V-II 30-BM-N V-II 30-BM-I V-II 30-N V-II 30-I	V-II 60 V-II 60-BM-N V-II 60-BM-I V-II 60-N V-II 60-I V-II 60-F	V-II 100 V-II 100-BM-N V-II 100-BM-I V-II 100-N V-II 100-I V-II 100-F	V-II 30/60 V-II 30/60-NZ V-II 30/60-K V-II 30/60-KF V-II 30/60-KF-LX V-II 30/60-KZ V-II 30/60-F	V-II 30/100 V-II 30/100-NZ V-II 30/100-K V-II 30/100-KF V-II 30/100-KF-LX V-II 30/100-KZ V-II 30/100-F V-II 30/60/100
Rated voltage:	230 V~	230 V~	230 V~	230 V~	230 V~
Rated frequency:	50 Hz	50 Hz	50 Hz	50 Hz	50 Hz
Rated power:	6 W	17 W	28 W	6/17 W	6/28 W
Protection class:	II	II	II	II	II
Degree of protection:	IPX5	IPX5	IPX5	IPX5	IPX5

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFIKAT ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

CERTIFICATE

No. B 011675 0010 Rev. 00

The endings on the marking plates.

-BM-N	motion detector with tracking control
-BM-I	motion detector incl. Interval and tracking control
-N	tracking control
-I	interval control
-F	humidity control
-NZ	base load 30 m ³ / h + overrun control
-K	comfort control
-KF	comfort control + remote control input
-KF-LX	comfort control + remote control input 230V
-KZ	comfort control + central control input

Tested according to: EN 60335-2-80:2003/A2:2009
 EN 60335-1:2012/A13:2017
 EN 62233:2008

Production Facility(ies): 011675

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT